CIVIL TECH LABS
5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph: 080 - 4114 2567, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AEE, Yelahanka Sub Division, BWSSB
Name of Work	Laying sockets to drains and providing flagging coping to 12th to 16th cross roads of Eastern side Sewerages beyond ward no. 02, of Yelahanka sub division
Name of Agency	Sri. V. R. Sridhar
Grade of Concrete	M-20
No. of cubes tested	3
Dimension of Specimen	150mm x 150mm x 150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS: 516-1959 (Reaffirmed 2013)

Sl. No.	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	Sample-1 (CTL)	20/02/2015	20/03/2015	28	8.18	470	20.89	21.26
2					8.19	480	21.33	
3					8.21	485	21.56	

Note:
1. The results of the tests apply to the items tested.
2. Report should not be reproduced except in full, without the written approval of the lab.
3. Any correction invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

Lab Incharge
Civil Tech Labs

AE ✓
AEE

CIVIL TECH LABS

CIVIL TECH LABS

#5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph: 080 - 4114 2567, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AEE, Velchala Sub Division, HNH
Name of Work	Improvement to drain and providing flagging course to CD no 16Rd cross road of Eastern side Velchala Jangaon to road no 02, of Velchala sub division
Name of Agency	Sri. Y. P. Sridhar
Grade of Concrete	M-20
No. of cubes tested	3
Dimension of Specimen	150mmX150mmX150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS: 516-1959 (Reaffirmed 2013)

Sl. No.	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (kN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	Sample-2 (DPC)	30/03/2015	27/04/2015	28	8.16	475	21.11	21.41
2					8.17	480	21.33	
3					8.19	490	21.78	

Note:
1. The results of the only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the Lab.
3. Any correction invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS BANGALORE

CIVIL TECH LABS
4 S, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph: 080 - 4114 2867, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AEE, Yelahanka Sub Division, BBMP
Name of Work	Improvements to drains and providing flagging course to 13th to 16th cross roads at Eastern side kundalpur layout in ward no. 02, of Yelahanka sub division.
Name of Agency	Sri. Y. R Sridhar
Grade of Concrete	M 20
No. of cubes tested	3
Dimension of Specimen	150mmx150mmx150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS 516-1959 (Reaffirmed 2013)

Sl. No.	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	Sample submitted by CTL	30/02/2015	25/03/2015	28	8.16	480	21.33	21.70
2					8.20	490	21.78	
3					8.22	495	22.00	

Note:
1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any corrections invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS BANGALORE

AE
@
AW

CIVIL TECH LABS
5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph: 080 - 4114 2867, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AFC Yelahanka Sub Division, BWSSB
Name of Work	Up/Down tracks to Gantry road providing flooring contract to 13th to 16th cross roads of Eastern side boundary at OHT in Ward no. 02 of Yelahanka sub division
Name of Agency	Sri. V. R. Srinivas
Grade of Concrete	M-20
No. of cubes tested	3
Dimension of Specimen	150mm(L)x150mm(B)x150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS: 516-1959 (Reaffirmed 2013)

Sl. No.	Identification	Date of Casting	Date of Testing	Age of test (Days)	Weight (Kg)	Failure Load (kN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	Sample-1 (OPC)	30/01/2015	20/02/2015	28	8.19	485	21.56	21.93
2					8.20	495	22.00	
3					8.21	500	22.22	

Note:
1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any corrections invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS
#5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph: 080 - 4114 2867, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AEE, Yelahanka Sub Division, BBMP
Name of Work	Improvements to drains and providing flagging course to 13th to 16th cross roads of Eastern side Kondappa Layout in ward no. 02 of Yelahanka sub division
Name of Agency	Sri. Y. R. Sridhar
Grade of Concrete	M-20
No. of cubes tested	3
Dimension of Specimen	150mmx150mmx150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS: 516-1959 (Reaffirmed 2013)

Sl. No.	Identification	Date of Casting	Date of Testing	Age at Test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	Sample-2	22/02/2015	22/03/2015	28	8.20	490	21.78	22.15
2					8.21	500	22.22	
3					8.23	505	22.44	

Note:
1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any correction invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS BANGALORE

CIVIL TECH LABS
5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph: 080 - 4114 2867, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AEE, Yelahanka Sub Division, BDMP
Name of Work	Rate/Estimate to change and providing dogging course to 12th to 16th cross roads of Eastern side Azadnagar layout in ward no. 02, of Yelahanka sub division
Name of Agency	M/s. Y. K. Srinivas
Grade of Concrete	M-30
No. of cubes tested	3
Dimension of Specimen	150mmx150mmx150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS: 516-1959 (Reaffirmed 2013)

Sl. No.	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	Sample-1	22/02/2015	22/03/2015	28	8.38	495	22.00	22.22
2					8.39	500	22.22	
3					8.40	505	22.44	

Note:
1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any corrections invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS BANGALORE

CIVIL TECH LABS
5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph: 080 - 4114 2857, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AEE, Yelahanka Sub Division, BBMP
Name of Work	Improvements to drains and providing flagging course to 13th to 16th cross roads of Eastern side kempapura layout in ward no. 02, of Yelahanka sub division.
Name of Agency	Sri. V. K. Sridhar
Grade of Concrete	M 20
No. of cubes tested	3
Dimension of Specimen	150mmx150mmx150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS 516-1959 (Reaffirmed 2013)

Sl. No.	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	Sample-1	22/02/2015	22/03/2015	28	8.17	475	21.11	21.41
2					8.18	480	21.33	
3					8.20	490	21.76	

Note:
1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any correction invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS BANGALORE

CIVIL TECH LABS
5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph: 080 - 4114 2867, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AEE, Yelahanka Sub Division, BBMP
Name of Work	Improvements to drains and providing flagging course to 13th to 16th cross roads of Eastern side kondappa Layout on road no. 02 of Yelahanka sub division
Name of Agency	Sri. V. B. Sridhar
Grade of Concrete	M-20
No. of cubes tested	3
Dimension of Specimen	150mmx150mmx150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS: 516-1959 (Reaffirmed 2013)

Sl. No.	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	Sample-3	22/02/2015	22/03/2015	28	8.16	490	21.80	21.78
2					8.18	490	21.78	
3					8.21	500	22.22	

Note:
1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any correction invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

CIVIL TECH LABS BANGALORE

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS
5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph. 080 - 4114 2867, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AEE, Yelahanka Sub Division, BBMP
Name of Work	Improvements to drains and providing flagging coarse to 150 ft to footpaths of Eastern side frontages thereof in ward no. 02 of Yelahanka sub division
Name of Agency	Sri. V. S. Srinivas
Grade of Concrete	M-30
No. of cubes tested	3
Dimension of Specimen	150mmx150mmx150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS: 516-1959 [Reaffirmed 2013]

Sl. No.	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	Sample-2	24/02/2015	24/03/2015	28	8.17	700	31.11	31.70
2					8.19	710	31.56	
3					8.22	730	32.44	

Note:
1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any correction invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS (BANGALORE)

CIVIL TECH LABS
#5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph: 080 - 4114 2867, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AEE, Yelahanka Sub Division, BBMP
Name of Work	Improvements to drains and providing flagging course to 13th to 16th cross roads of Eastern side kodigehalli layout in ward no. 02 of Yelahanka sub division.
Name of Agency	Sri. Y. R. Sridhar
Grade of Concrete	M30
No. of cubes tested	3
Dimension of Specimen	150mmx150mmx150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS: 516-1959 (Reaffirmed 2013)

Sl. No.	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (kN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	Sample-3	24/02/2015	24/03/2015	28	8.17	710	31.56	32.30
2					8.19	730	32.44	
3					8.20	740	32.89	

Note:
1. The results relate only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the lab.
3. Any corrections invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS
#5, 1st Cross, Srinivasa Colony, Mission Road, Bangalore - 560027
Ph: 080 - 4114 2867, Email: civiltechlabs@gmail.com

TEST REPORT

COMPRESSIVE STRENGTH TEST ON CONCRETE CUBES

Name & Address of the Customer	AEE, Yelahanka Sub Division, BBMP
Name of Work	Improvements to drains and providing flagging cover to 12th to 16th cross roads of Eastern side footpaths in front of ward no. 02 of Yelahanka sub division.
Name of Agency	Sri. Y. K. Shankar
Grade of Concrete	M30
No. of cubes tested	3
Dimension of Specimen	150mm x 150mm x 150mm
Cross Sectional Area	22500 mm²
Technical Reference	IS 516-1959 (Reaffirmed 2013)

Sl. No.	Identification	Date of Casting	Date of Testing	Age at test (Days)	Weight (Kg)	Failure Load (KN)	Compressive Strength (N/mm²)	Avg Compressive Strength (N/mm²)
1	Sample-3	24/02/2015	24/03/2015	28	8.20	690	30.67	31.56
2					8.22	710	31.56	
3					8.24	730	32.44	

Note:
1. The results pertain only to the items tested.
2. Report shall not be reproduced except in full, without the written approval of the Lab.
3. Any correction invalidates this report.
4. The results are based on the test conducted on samples supplied by the customer.

Lab Incharge
Civil Tech Labs

CIVIL TECH LABS BANGALORE

A Synonym to quality